

Pedestrian Flooring Selection Guide

Minimum Pendulum or Ramp Recommendations for Specific Locations

LOCATION	PENDULUM	RAMP
External colonnade, walkways and pedestrian crossings	W	R10
External ramps	V	R11
Entry foyers hotel, office, public buildings – wet	X	R10
Entry foyers hotel, office, public buildings – dry	Z	R9
Shopping centre excluding food court	Z	R9
Shopping centre – food court	X	R10
Internal ramps, slopes (greater than 2 degrees) – dry	X	R10
Lift lobbies above external entry level	Z	R9
Other separate shops inside shopping centres	Z	R9
Other shops with external entrances – entry area	X	R10
Fast food outlets buffet food servery areas	X	R10
Hospitals and aged care facilities – dry areas	Z	R9
Hospital and aged care facilities – en suites	X	A or R10
Supermarket aisles except fresh food areas	Z	R9
Shop and supermarket fresh fruit and vegetable areas	X	R10
Communal changing rooms	X	A
Swimming pool surrounds and communal shower rooms	W	B
Swimming pool ramps and stairs leading into water	V	C
Toilet facilities in offices, hotels, shopping centres	X	R10
Undercover concourse areas of sports stadium	X	R10
Accessible internal stair nosings (dry) – handrails present	X	R10
Accessible internal stair nosings (wet) – handrails present	W	B or R11
External stair nosings	W	R11

NOTE:

1. Appropriate measures need to be taken to exclude casual water from dry areas.
2. All floors with a wet pendulum classification of Z should have a dry floor friction classification of F unless normal usage dictates that the floor should have a low dry coefficient of friction, e.g. dance floors.